

CUSTOM SERIES

OUTSWING WOOD DOORS

FLORIDA STATE APPROVAL

CODE VERSION: FLORIDA BUILDING CODE 2023 - 8th EDITION
 APPROVED FOR USE INSIDE HVHZ AND OUTSIDE HVHZ
 CATEGORY: EXTERIOR DOORS -- SUBCATEGORY: SWINGING EXTERIOR DOOR ASSEMBLY
 IMPACT RESISTANT: LARGE MISSILE




GENERAL NOTES:

- 1- CODE: THIS PRODUCT HAS BEEN TESTED UNDER PROTOCOLS TAS 201, 202 AND 203 AND DESIGNED IN ACCORDANCE WITH THE FBC 2023 - 8th EDITION INCLUDING THE HIGH VELOCITY HURRICANE ZONE (HVHZ).
- 2- DEFINITION: THIS PRODUCT IS AN EXTERIOR OUT SWING WOOD TYPE DOOR DESIGNED, CONSTRUCTED AND TESTED TO PROVIDE PROTECTION FROM HURRICANE FORCE WINDS AND WIND BORNE DEBRIS (LARGE & SMALL MISSILE) WITHIN THE ALLOWABLE DESIGNED PRESSURES AND LIMITATIONS STATED IN THIS APPROVAL.
- 3- POSTING: PRODUCT SHALL BE LABELED AS PER FBC SECTION 1703.5. THE PERMANENT LABEL, MARKING OR ETCHING SHALL PROVIDE TRACEABILITY TO THE MANUFACTURER AND PRODUCT.
- 4- LOADS: DESIGNED LOAD CALCULATED BASED ON THE ASCE 7-22 AND PROVIDED BY A PROFESSIONAL ARCHITECT OR ENGINEER FOR EACH SPECIFIC PROJECT. THE CALCULATED DESIGNED PRESSURE MUST NOT EXCEED THE ALLOWABLE PRESSURES HERE IN SPECIFIED. THE ULTIMATE DESIGN PRESSURES, AS DETERMINED FROM ASCE 7-22, ARE PERMITTED TO BE MULTIPLIED BY 0.6 AS PER THE FLORIDA BUILDING CODE.
- 5- MATERIAL:
 - 5.1- ALL WOOD TO BE WITH MINIMUM 0.55 SPECIFIC GRAVITY CORRECTED FOR 12% MOISTURE CONTENT PER NDS 0.58 RAW. DENSITY OF BUTCHER BLOCK CONSTRUCTION WITH VENEER 0.535 g/cm³.
 - 5.2- GLAZING: LAMINATED IMPACTED RATED AS SPECIFIED IN THIS APPROVAL
- 6- FASTENERS: ASSEMBLY SCREWS AND ANCHORS SHALL BE AS SPECIFIED IN THE CURRENT SET OF DRAWINGS.
- 7- USE: IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR, ARCHITECT OR ENGINEER OF RECORD TO VERIFY THE FOLLOWING:
 - 7.1- THE STABILITY OF THE STRUCTURE WHERE THE PRODUCT IS TO BE ATTACHED INSURING PROPER ANCHORAGE.
 - 7.2- THE SITE SPECIFIC PROJECT CRITERIA, SUCH AS BUT NOT LIMITED TO, LOCAL CODE REQUIREMENTS, DESIGNED PRESSURES ETC.
 - 7.3- THAT THIS APPROVAL IS ADEQUATE TO THE SPECIFIC PROJECT.

TABLE OF CONTENTS:

SHEET	DESCRIPTION
1 OF 16	GENERAL NOTES, TABLE OF CONTENTS, TESTED UNITS
2 OF 16	MODEL 1 ELEVATIONS
3 OF 16	MODEL 2 ELEVATIONS
4 OF 16	MODEL 3 ELEVATIONS
5 OF 16	MODEL 4 ELEVATIONS
6 OF 16	MODEL 6 ELEVATIONS
7 OF 16	MODELS 1, 2, 3, 4 AND 6 SECTIONS
8 OF 16	MODEL 3 AND 6 SECTIONS
9 OF 16	MODELS 1, 2, 3 AND 4 GLAZING DETAILS AND BILL OF MATERIALS
10 OF 16	MODEL 6 GLAZING DETAILS AND BILL OF MATERIALS
11 OF 16	MODELS 1, 2, 3, 4 AND 6 COMPONENTS
12 OF 16	MODEL 5 ELEVATIONS
13 OF 16	MODELS 5 SECTIONS, BILL OF MATERIALS AND COMPONENTS
14 OF 16	FRAMING ANCHORAGE
15 OF 16	QUALIFIED PANELS AND FRAMING CONFIGURATIONS
16 OF 16	SASH & FRAME ASSEMBLY

TESTED UNITS




Digitally signed by Pedro Figueiredo
 Date: 2023.10.19 07:18:32 -04'00'
 DIGITALLY SIGNED FOR 16 PAGES
 THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO, PE 52609 ON THE DATE INDICATED HERE.



Pedro De Figueiredo
 10/19/2023



ENGINEERING SERVICES - CA 32459
 9715 W. BROWARD BLVD.
 PLANTATION, FL 33324
 PPMF@AOL.COM
 ENGINEER SEAL
 PEDRO DE FIGUEIREDO
 PE 52609



WIND STRUCTURAL: PD= +65 PSF, -65 PSF
 WIND CYCLIC: PD= +65 PSF, -65 PSF
 IMPACT RATING: LARGE & SMALL MISSILE
 OPERATING FORCE
 WATER RESISTANCE: ASTM E331, 11.25 PSF (15% OF +75 PSF)
 AIR INFILTRATION: ASTM E283
 FORCE ENTRY: ASTM F588

WIND STRUCTURAL: PD= +65 ** PSF, -65 PSF
 WIND CYCLIC: PD= +65 PSF, -65 PSF
 IMPACT RATING: LARGE & SMALL MISSILE

** PRODUCT POSITIVE PRESSURE TO BE LIMITED TO +60 PSF FOR INSTALLATIONS WITHOUT AN OVERHANG MEETING THE OH ratio= OH length/ OH height DOOR COVERAGE (FBC SECTION 1709.5.1)


OPERATING FORCE
 WATER RESISTANCE: ASTM E331
 9 PSF -- (15% OF +60 PSF)
 AIR INFILTRATION: ASTM E283
 FORCE ENTRY: ASTM F588

PRODUCT:
CUSTOM SERIES
 OUTSWING DOORS
 LARGE & SMALL MISSILE
 IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
 222 NE 27TH STREET
 MIAMI- FLORIDA- 33137
 TEL: (561) 939-3368
 FAX: (877) 839-2220

SCALE:
 NA
 DATE:
 10/19/2023
 DRAWING #
 23-202
 SHEET
 1 OF 16


MODEL I




EXTERIOR SIDE ELEVATION
RECTANGULAR TYPE PAIR DOOR XX



SEE SHEET 14 TO SELECT ANCHOR OPTIONS



LOCK HARDWARE:



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:

NA

DATE:

10/19/2023

DRAWING #

23-202

SHEET

2 OF 16

MODEL I
RECTANGULAR SWING-OUT
PAIR DOOR XX: (MAX. 74 1/2" X 121 9/16")
SINGLE DOOR X: (MAX. 38 3/8" X 121 9/16")

PD= +65 PSF, -65 PSF


OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

HARDWARE NOTES:


- 1- SURFACE BOLTS:** (4) SURFACE BOLTS BY CUSTOM PART #H-3 WERE INSTALLED IN THE ACTIVE AND INACTIVE LEAVES AT TOP AND BOTTOM.
THE BOTTOM SURFACE BOLTS WERE ATTACHED USING LOCK GUIDES FROM THE EDGE OF THE ASTRAGAL AT: 3 7/8", 5/8" AND 6 5/8" USING (2) #8X1 1/2" S5 PFH SMS PER LOCATION.
THE TOP SURFACE BOLTS WERE ATTACHED USING LOCK GUIDES FROM THE TOP EDGE OF THE ASTRAGAL AT: 3 7/8", 5/8", 9" AND 18 1/2" USING (2) #8 X 1 1/2" S5 PFH SMS PER LOCATION. A LOCK BAR REINF. GUIDE WAS INSTALLED USING (2) #1 2X3 S5 PFH SMS.
- 2- STRIKE PLATES:**
 - 2.1- FRAME HEAD & SILL: A 1 1/8X2X1 1/4 GA THICK S5 STRIKE PLATE WERE INSTALLED ON THE HEADER AND SILL USING (4) #1 2X3 S5 PFH SMS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
 - 2.2- INACTIVE SASH: (3) STRIKE PLATES WERE INSTALLED IN THE INACTIVE LEAF AT CORRESPONDING POSITIONS AND WERE ATTACHED USING (4,3,4) #10X3 S5 PFH SMS STARTING FROM BOTTOM OF THE LEAF
- 3- DOOR HANDLE:** A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK:** A (3) POINT WITH AN ADDITIONAL LATCHING POINT, CUSTOM # H1 WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AT 13.5, 40.5, 43.375, 68.75 FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (9) #10X2 S5 PFH SMS AT 10" AND 9" OC AVERAGE FROM THE BOTTOM OF THE DOOR LEAF.
- 5- HINGES:** (4) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (2) #1 2X3 / (2) #1 2X 1 1/4 PFH SMS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #1 2X3 PFH SMS.

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609


MODEL 2




EXTERIOR SIDE ELEVATION
ARCHED TYPE PAIR DOOR XX



SEE SHEET 14 TO SELECT ANCHOR OPTIONS



H4 W/ 1/2" DIAMX2" LONG
SHEAR PIN W/ 3/4" THROW,
11GA SS REINF. PLATE W/ A
GUIDE SHEAR ROD. THE PLATE
WERE GLUE AND ATTACHED W/
(3) #12X3 SS PFH SMS AND
(4) #10X 1 1/2" SS PFH SMS



Pedro De Figueiredo
10/19/2023



PRODUCT:
**CUSTOM SERIES
OUTSWING DOORS**
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
3 OF 16

MODEL 2
RECTANGULAR SWING-OUT
PAIR DOOR XX: (MAX. 74 1/2" X 122 3/4")
SINGLE DOOR X: (MAX. 38 3/8" X 122 3/4")

PD= +65 PSF, -65 PSF


OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

HARDWARE NOTES:

- 1- FLUSH BOLTS: THE INACTIVE DOOR LEAF CONTAINED A CONCEALED FLUSH BOLT CUSTOM PART # H4 WITH 1/2" DIAMX2" LONG SHEAR PIN WITH 3/4" THROW AT TOP AND BOTTOM. THE LOCK CONTAINED AN 11GA SS REINFORCEMENT PLATE WITH A GUIDE SHEAR ROD AT TOP & BOTTOM. THE REINF. PLATE WERE GLUE USING ASHALAND ISOGRIP SP 3030 D AND WERE ATTACHED USING (3) #12X3 SS PFH SMS FROM BOTTOM AND (4) #10X 1 1/2" SS PFH SMS FROM INTERIOR EDGE.
- 2- STRIKE PLATES:
 - 2.1- FRAME HEAD & SILL: a 1X2X0.244 THICK SS STRIKE PLATE WERE INSTALLED ON THE HEADER AND SILL USING (4) #12X3 SS PFH SMS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
 - 2.2- INACTIVE SASH: (4) 0.8X6.9" LONG STRIKE PLATE WERE INSTALLED IN THE INACTIVE LEAF EACH USING (4) #10X2 PFH SMS. THE STRIKE PLATE WERE INSTALLED TO MATCH THE LOCK POINTS FROM THE BOTTOM OF THE LEAF. THE SECOND STRIKE PLATE HAS TWO CUT-OUTS
- 3- DOOR HANDLE: A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK: A (4) POINT WITH AN ADDITIONAL LATCHING POINT. CUSTOM # H1A WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AS INDICATED IN THE ILLUSTRATION ABOVE FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (13) #10X2 SS PFH SMS AT 9 3/8" FROM THE BOTTOM OF THE DOOR AND 8" OC AVERAGE.
- 5- HINGES: (4) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #12X3 PFH SMS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #12X3 PFH SMS.

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609



EXTERIOR SIDE ELEVATION
RECTANGULAR PAIR DOOR
O-XX-O WITH SIDELITES

MODEL 3

RECTANGULAR SWING-OUT W/ SIDELITES
PAIR DOOR XX: (MAX. 74 5/8" X 122 1/2")
SINGLE DOOR X: (MAX. 38 7/16" X 122 1/2")
SIDELITE O: (MAX. 45" X 122 1/2")


PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

SASH CONSTRUCTION:

THE DOOR LEAF CORNERS AND INTERMEDIATE CONNECTIONS WERE RABBET BUTT JOINED USING MORTISE AND TENON CONNECTIONS.
BOTTOM RAIL TO VERTICAL STILE: 6 3/4 X 3/4 X 1 7/8" TENON INTO THE STILE
TOP RAIL TO VERTICAL STILE: 4 1/4 X 3/4 X 1 7/8" LONG TENON INTO THE STILE
INTERMEDIATE RAIL TO VERTICAL STILE: 4 1/4 X 3/4 X 1 7/8" LONG TENON INTO THE STILE
INTERMEDIATE RAIL TO HORIZONTAL RAILS: 4 1/4 X 3/4 X 1 7/8" LONG TENON INTO RAILS
THE ASTRAGAL WAS ATTACHED TO THE DOOR SASH USING (11) #8X1 WOOD SCREWS AT 11" OC.

MODEL 3




FRAME ANCHORAGE LAY-OUT
SEE SHEET 14 FOR DETAILS

LOCK HARDWARE:
SAME AS SHEET 3

SEE SHEET 14 TO SELECT ANCHOR OPTIONS

HARDWARE NOTES:

- 1- FLUSH BOLTS: THE INACTIVE DOOR LEAF CONTAINED A CONCEALED FLUSH BOLT CUSTOM PART # H4 WITH 1/2" DIAM X2" LONG SHEAR PIN WITH 3/4" THROW AT TOP AND BOTTOM. THE LOCK CONTAINED AN 1 1/2" GA 55 REINFORCEMENT PLATE WITH A GUIDE SHEAR ROD AT TOP & BOTTOM. THE REINFORCING PLATE WERE ATTACHED USING (3) #1 2X3 55 PFH 5MS FROM BOTTOM AND (4) #1 0X 1 1/2" 55 PFH 5MS FROM INTERIOR EDGE. THE FLUSH BOLTS WERE 2 5/8" FROM THE VERTICAL END OF THE LOCK STILE.
- 2- STRIKE PLATES:
 - 2.1- FRAME HEAD & SILL: A 1 1/2X3X1/4 THICK STEEL STRIKE PLATES WERE INSTALLED ON THE HEADER AND SILL USING (4) #1 2X3 PFH 5MS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
 - 2.2- INACTIVE SASH: (4) 0.8X6.9" LONG STRIKE PLATE WERE INSTALLED IN THE INACTIVE LEAF EACH USING (4) #1 0X2 PFH 5MS, EXCEPT 2ND FROM THE BOTTOM WITH (3) SCREWS SAME TYPE. THE STRIKE PLATE WERE INSTALLED TO MATCH THE LOCK POINTS FROM THE BOTTOM OF THE LEAF. THE SECOND STRIKE PLATE HAS TWO CUT-OUTS
- 3- DOOR HANDLE: A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK: A (4) POINT WITH AN ADDITIONAL LATCHING POINT, CUSTOM # H1A WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AS INDICATED IN THE ILLUSTRATION AS PER SHEET 3 OF 14 FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (15) #1 0X2 55 PFH 5MS AT 8 3/4" FROM THE BOTTOM OF THE DOOR AND 7 7/8" OC AVERAGE.
- 5- HINGES: (5) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #1 2X3 PFH 5MS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #1 2X3 PFH 5MS.



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS

222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA



DATE:
10/19/2023

DRAWING #
23-202



SHEET
4 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODEL 4



SEE SHEET 14 TO SELECT ANCHOR OPTIONS



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220


SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
5 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODEL 4
RECTANGULAR SWING-OUT 1 3/4"
SINGLE DOOR X: (MAX. 50 1/2" X 122 1/2")
PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

HARDWARE NOTES:
1- DOOR HANDLE: ACTIVATING THE LATCH WAS INSTALLED AT 42" FROM THE BOTTOM OF THE DOOR.
2- ACTIVE DOOR LOCK: A (5) POINT LOCKING MECHANISM WITH AN ADDITIONAL LATCH, # H1A - 5 POINT BY CUSTOM, WAS INSTALLED ON THE LEAF. EACH POINT LOCK PROTRUDED 1 3/16". THE CORRESPONDING (5) 6 7/8" X 0.80 X 0.112" PAINTED STEEL STRIKES PLATES WITH 1.73" X 0.50" SLOT WERE ATTACHED TO THE DOOR JAMB AS ILLUSTRATED ABOVE
3- HINGES: (5) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #12X3 PFH SMS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #12X3 PFH SMS.



EXTERIOR SIDE ELEVATION
RECTANGULAR TYPE PAIR DOOR W/ TRANSOM XX-O


MODEL 6
RECTANGULAR W/ TRANSOM SWING-OUT
PAIR DOOR XX-O: (MAX. 74 1/2" X 160 3/8")
SINGLE DOOR X-O: (MAX. 38 3/8" X 160 3/8")

PD= +65 PSF, -65 PSF

** PRODUCT POSITIVE PRESSURE TO BE LIMITED TO
+60 PSF FOR INSTALLATIONS WITHOUT AN OVERHANG
MEETING THE OH ratio= OH length/ OH height
DOOR COVERAGE (FBC SECTION 1709.5.1)

OPERATING FORCE
WATER RESISTANCE: ASTM E33 I
9 PSF -- (15% OF +60 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

MODEL 6



** FBC SECTION 2411.3.3.1 FOR EACH FIXED
GLASS SILL WITH WIDTH MORE THAN 3 FEET
TO HAVE TWO APPROVED NEOPRENE SETTING
BLOCKS 70-90 SHORE A DUROMETER
HARDNESS

CLUSTER OF
(4) ANCHORS
AT 4" OC


STRIKE PLATE SECURED
TO INACTIVE STILE
W/ (4) #12X1 1/2 PFH SMS

STRIKE PLATE SECURED
TO INACTIVE STILE
W/ (4) #12X1 1/2 PFH SMS

CLUSTER OF
5 ANCHORS
AT 4" OC

ANCHORS AT
MAX. 12" OC

CLUSTER OF
3 ANCHORS
AT 3" OC



LOCK HARDWARE:


CUSTOM 4 POINT
LOCK INSTALLED TO
THE ACTIVE STILE
W/ (13) #10X2 PFH SMS
AT AVG 8" OC

DUMMY HANDLE

STRIKE PLATE SECURED
TO INACTIVE STILE
W/ (4) #12X1 1/2 PFH SMS

HARDWARE NOTES:

- 1- FLUSH BOLTS: CUSTOM PART H-4 INSTALLED IN THE INACTIVE LEAF 17 1/4" FROM THE TOP AND 19 1/2" FROM THE BOTTOM OF THE SASH. THE LOCK CONTAINED AN 1 1/2" GA SS REINFORCEMENT PLATE WITH A GUIDE SHEAR ROD AT TOP AND BOTTOM. THE REINF. PLATE WERE GLUED USING ASHLAND ISOGRIP 5P 3030D AND WERE ATTACHED USING (3) #12X3 SS PFH SMS FROM BOTTOM AND (4) #10X1 1/2" SS PFH SMS FROM THE INTERIOR EDGE.
- 2- STRIKE PLATES:
 - 2.1- FRAME HEAD & SILL: A 1X2X0.244 THICK SS STRIKE PLATE WERE INSTALLED ON THE HEADER AND SILL USING (4) #12X3 SS PFH SMS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
 - 2.2- INACTIVE SASH: (4) 0.8X6.9" LONG STRIKE PLATES WERE INSTALLED IN THE INACTIVE LEAF USING (4) #12 X 1 1/2" PFH SMS.
- 3- DOOR HANDLE: A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK: A (4) POINT WITH AN ADDITIONAL LATCHING POINT, CUSTOM # H1A WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AT 12, 41.5, 67 AND 92 FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (13) #10X2 SS PFH SMS AT 9.375", 16.375, 25.25, 34.5, 46.375, 55.5, 64.5, 71.25, 78.75, 80.875, 90, 96.75, 105 FROM THE BOTTOM OF THE DOOR LEAF.
- 5- HINGES: (5) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #12X3 PFH SMS.



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.








PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
6 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODELS 1, 2, 3, 4 AND 6 - SECTIONS



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.






PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220



SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
7 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODELS 3 AND 6 - SECTIONS



** FBC SECTION 2411.3.3.1 FOR EACH FIXED GLASS SILL WITH WIDTH MORE THAN 3 FEET TO HAVE TWO APPROVED NEOPRENE SETTING BLOCKS 70-90 SHORE A DUROMETER HARDNESS



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
**CUSTOM SERIES
OUTSWING DOORS**
LARGE & SMALL MISSILE
IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
8 OF 16


ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODELS 1, 2, 3 AND 4 - BILL OF MATERIALS & GLAZING DETAILS

GLAZING DETAILS



GLASS GLAZING METHOD:
GLASS AND GLAZING STOP WERE WET GLAZED USING DOW 995 SILICONE AND FURTHER ATTACHED USING #8X2 PFH SMS.



WOOD PANEL GLAZING METHOD:
PANEL AND GLAZING STOP WERE WET GLAZED USING DOW 995 SILICONE AND FURTHER ATTACHED USING #8X2 PFH SMS.

BILL OF MATERIALS:

PART#	DESCRIPTION	MATERIAL
1	6 5/8 X 1 3/4 HEADER/ JAMB	LAMINATED WOOD
2	6 5/8 X 1 3/4 SILL	SOLID WOOD
3	7 X 2 1/4 HINGE STILE	BUTCHED BLOCK W/ VENEER
4	7 X 2 1/4 LOCK STILE	BUTCHED BLOCK W/ VENEER
5	7 X 2 1/4 TOP RAIL	BUTCHED BLOCK W/ VENEER
6	9 3/8 X 2 1/4 BOTTOM RAIL	BUTCHED BLOCK W/ VENEER
7	7 X 2 1/4 INTERMEDIATE RAIL	BUTCHED BLOCK W/ VENEER
8	3/4 X 3/16 INSIDE MOULDING	SOLID WOOD
9	1 1/4 X 1 1/8 GLAZING STOP	SOLID WOOD
10	1 1/2 X 5/8 INACTIVE ASTRAGAL	SOLID WOOD
11	1 3/4 X 1 1/4 ACTIVE ASTRAGAL	LAMINATED WOOD
12	2 1/4" LAMINATED WD PANEL	LAMINATED WOOD
13	1/2" IMPACT GLASS	LAMINATED ANNEAL GLASS
14	DOW CORNING 995	STRUCTURAL SILICONE
15	1.22X.51 WEAR STRIP	ALUMINUM
16	1 1/2 X 3/4 DRIP CAP	SOLID WOOD
16.1	2.3X3 TRANSOM SASH	BUTCHED BLOCK W/ VENEER

ASSEMBLY SCREWS & NAILS:


PART#	DESCRIPTION	MATERIAL
S1	#10 X 3" PFH SMS	ZINC PLATED STEEL
S2	#6 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S3	18 GA X 1" BRAD NAIL	GALVANIZED STEEL
S4	#6 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S5	#8 X 2" PFH SMS	ZINC PLATED STEEL
S6	#12 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S7	#12 X 3" PFH SMS	ZINC PLATED STEEL
S8	#8 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S9	#10 X 2" PFH SMS	ZINC PLATED STEEL

DOOR HARDWARE:

PART#	DESCRIPTION	MATERIAL
H1	CUSTOM 4 POINT LOCK	STEEL
H2	4.5X4.5 CUSTOM HINGES	SOLID BRASS
H3	CUSTOM SURFACE BOLTS	STEEL
H4	1 1/8"X2"X1 1/2 GA STRIKE PLATE	STAINLESS STEEL

DOOR WEATHER STRIPPING:

PART#	DESCRIPTION	MATERIAL
W1	QEBD 650 KERF	BY SCHLEGEL
W2	BULB VINYL	NEOPRENE
W3	QEZD 320 FLAT	BY SCHLEGEL



Pedro De Figueiredo
10/19/2023



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA

DATE:
10/19/2023

DRAWING #
23-202


SHEET
9 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PFMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.


MODELS 6 - BILL OF MATERIALS & GLAZING DETAILS

GLAZING DETAILS




GLASS GLAZING METHOD:
GLASS AND GLAZING STOP WERE WET GLAZED USING DOW 995 SILICONE AND FURTHER ATTACHED USING #8X2 PFH SMS.


GLAZING DESIGN COMPLIANT W/ ASTM E1300




WOOD PANEL GLAZING METHOD:
PANEL AND GLAZING STOP WERE WET GLAZED USING DOW 995 SILICONE AND FURTHER ATTACHED USING #8X2 PFH SMS.



TRANSOM GLAZING



DOOR GLAZING



DOOR WOOD PANEL

BILL OF MATERIALS:

PART#	DESCRIPTION	MATERIAL
1	6 5/8 X 1 3/4 HEADER/ JAMB	LAMINATED WOOD
2	6 5/8 X 1 3/4 SILL	SOLID WOOD
3	7 X 2 1/4 HINGE STILE	BUTCHED BLOCK W/ VENEER
4	7 X 2 1/4 LOCK STILE	BUTCHED BLOCK W/ VENEER
5	7 X 2 1/4 TOP RAIL	BUTCHED BLOCK W/ VENEER
6	9 3/8 X 2 1/4 BOTTOM RAIL	BUTCHED BLOCK W/ VENEER
7	7 X 2 1/4 INTERMEDIATE RAIL	BUTCHED BLOCK W/ VENEER
8	3/4 X 3/16 INSIDE MOULDING	SOLID WOOD
9	1 1/4 X 1 1/8 GLAZING STOP	SOLID WOOD
10	1 1/2 X 5/8 INACTIVE ASTRAGAL	SOLID WOOD
11	1 3/4 X 1 1/4 ACTIVE ASTRAGAL	LAMINATED WOOD
12	2 1/4" LAMINATED WD PANEL	LAMINATED WOOD
13	1/2" IMPACT GLASS	LAMINATED ANNEAL GLASS
14	DOW CORNING 995	STRUCTURAL SILICONE
15	1.22X.51 WEAR STRIP	ALUMINUM
16	1 1/2 X 3/4 DRIP CAP	SOLID WOOD
16.1	2.3X3 TRANSOM SASH	BUTCHED BLOCK W/ VENEER

ASSEMBLY SCREWS & NAILS:


PART#	DESCRIPTION	MATERIAL
S1	#10 X 3" PFH SMS	ZINC PLATED STEEL
S2	#6 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S3	18 GA X 1" BRAD NAIL	GALVANIZED STEEL
S4	#6 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S5	#8 X 2" PFH SMS	ZINC PLATED STEEL
S6	#12 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S7	#12 X 3" PFH SMS	ZINC PLATED STEEL
S8	#8 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S9	#10 X 2" PFH SMS	ZINC PLATED STEEL

DOOR HARDWARE:

PART#	DESCRIPTION	MATERIAL
H1	CUSTOM 4 POINT LOCK	STEEL
H2	4.5X4.5 CUSTOM HINGES	SOLID BRASS
H3	CUSTOM SURFACE BOLTS	STEEL
H4	1 1/8"X2"X1 1/2 GA STRIKE PLATE	STAINLESS STEEL

DOOR WEATHER STRIPPING:

PART#	DESCRIPTION	MATERIAL
W1	QEBD 650 KERF	BY SCHLEGEL
W2	BULB VINYL	NEOPRENE
W3	QEZD 320 FLAT	BY SCHLEGEL



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA


DATE:
10/19/2023

DRAWING #
23-202


SHEET
10 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609


MODELS 1, 2, 3, 4 AND 6 - COMPONENTS




1- HEADER / JAMB
LAMINATED MAHOGANY WOOD
OR SOLID MAHOGANY WOOD




2A- ALUMINUM WEAR STRIP
SECURED TO SILL WITH #8X1 1/4" FHWS
SPACED AT 11"OC




2- SILL
SOLID MAHOGANY WOOD




5- DOOR TOP RAIL
BUTCHER BLOCK MAHOGANY WOOD
LAMINATED MAHOGANY FOR ARCHED UNITS




16- TRANSOM SASH
BUTCHER BLOCK MAHOGANY WOOD




16- DOOR BOTTOM RAIL DRIP CAP
SOLID MAHOGANY WOOD
INSTALLED WITH #6 X 1 1/2 PPHSMS AT 9 1/2" OC




3- DOOR HINGE STILE
BUTCHER BLOCK MAHOGANY WOOD




7- DOOR INTERMEDIATE RAIL
BUTCHER BLOCK MAHOGANY WOOD




8- DOOR INTERIOR
DECORATIVE MOULDING
SOLID MAHOGANY WOOD




9- DOOR GLAZING STOP
SOLID MAHOGANY WOOD




4- DOOR MEETING STILE
BUTCHER BLOCK MAHOGANY WOOD




6- DOOR BOTTOM RAIL
BUTCHER BLOCK MAHOGANY WOOD



10- INACTIVE LEAF ASTRAGAL
SOLID MAHOGANY WOOD



11- ACTIVE LEAF ASTRAGAL
LAMINATED MAHOGANY WOOD



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA


DATE:
10/19/2023

DRAWING #
23-202


SHEET
11 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609


MODEL 5



EXTERIOR SIDE ELEVATION
RECTANGULAR TYPE SINGLE DOOR X
BUTCHER BLOCK ONE SLAB CONSTRUCTION




SEE SHEET 14 TO SELECT ANCHOR OPTIONS



4 POINT LOCK MODEL 5000 BY VACHETTE INSTALLED TO THE ACTIVE LEAF. THE MAIN LOCK WAS LOCATED AT 37 7/8" FROM THE BOTTOM. LOCK WAS SECURED BY (15) #6X2 PFH SMS SPACED AT 8" DC AVERAGE.

HARDWARE NOTES:

- 1- DOOR LOCK: A (4) POINT LOCKING MECHANISM MODEL 5000 BY VACHETTE, WAS INSTALLED ON THE LEAF. EACH POINT LOCK PROTRUDED 1 3/16" AND WERE LOCATED AS PER ILLUSTRATION ABOVE. THE MAIN LATCH WAS LOCATED AT 37 7/8" FROM THE BOTTOM OF THE LEAF. THE FOUR POINT LOCK ASSEMBLY WAS ATTACHED TO THE LEAF USING (15) #6X2 PFH SMS 1 1/2" FROM THE BOTTOM AND 7 5/8" OC AVERAGE.
- 2- STRIKE PLATES: THE STRIKE PLATES WERE INSTALLED AT THE LOCATIONS CORRESPONDING TO THE LOCK POINTS. EACH STRIKE PLATE WAS ATTACHED TO THE FRAME JAMB USING (4) #10X2" PFH SMS EXCEPT THE STRIKE PLATE CORRESPONDING TO THE LATCH LOCK OR 2ND POINT FROM THE BOTTOM WHICH ONLY USED (3) #10X2" PFH SMS
- 3- HINGES: (4) PIVOTA DX 300 3-D CP SAFE HINGES BY BASYS WERE ATTACHED TO THE DOOR LEAF AS PER ELEVATION. THE HINGES WERE SECURED TO THE DOOR JAMBS WITH (4) SCREWS ((2) #12X1 1/2" PFH SMS AND (2) 1/4 X 3 1/4") AND SECURED TO THE LEAF WITH (4) 1/4X2 1/2" PFH SMS.
- 4- REINFORCEMENT: (6) 5/8" DIAMETER X 33 3/4" LONG STEEL RODS LOCATED AS PER ELEVATION INSTALLED IN THE BUTCHER BLOCK CONSTRUCTED AREA.



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
12 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODEL 4
RECTANGULAR BUTCHER BLOCK SLAB SWING-OUT
SINGLE DOOR X: (MAX. 45 1/2" X 121 3/4")
PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588




ALTERNATE DOOR PANELS

NOTES:

- 1- ILLUSTRATED ABOVE IS JUST FOR A FEW VARIATIONS OF MANY POSSIBLE COMBINATIONS.
- 2- COMBINATIONS OF ALTERNATE DOOR PANELS ARE ACCEPTABLE IF DESIGN ARE MADE WITH SURFACE APPLIED MOLDING OVER THE MAIN 2-1/4" BUTCHER BLOCK SLAB OR VENEER GROOVING.

MODEL 5 - SECTIONS, BILL OF MATERIALS AND COMPONENTS



ENGINEER
 9715 W. BROWARD BLVD.
 PLANTATION, FL 33324
 PPMF@AOL.COM
 ENGINEER SEAL
 PEDRO DE FIGUEIREDO
 PE 52609



PRODUCT:
CUSTOM SERIES
 OUTSWING DOORS
 LARGE & SMALL MISSILE
 IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
 222 NE 27TH STREET
 MIAMI-FLORIDA- 33137
 TEL: (561) 939-3368
 FAX: (877) 839-2220

SCALE:
 NA
 DATE:
 10/19/2023
 DRAWING #
 23-202
 SHEET
 13 OF 16

BILL OF MATERIALS:

PART#	DESCRIPTION	MATERIAL
1	6 5/8 X 1 3/4 HEADER/ JAMB	LAMINATED WOOD
2	6 5/8 X 1 3/4 SILL	SOLID WOOD
12.1	2 1/4" BUTCHER BLOCK PANEL	BUTCHER BLOCK WOOD
15	1.22 X .51 WEAR STRIP	ALUMINUM

ASSEMBLY SCREWS & NAILS:








PART#	DESCRIPTION	MATERIAL
S1	#10 X 3" PFH SMS	ZINC PLATED STEEL
S9	#10 X 2" PFH SMS	ZINC PLATED STEEL
S10	#12 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S11	1/4" X 3 1/4" PFH SMS	ZINC PLATED STEEL
S12	1/4" X 2 1/2" PFH SMS	ZINC PLATED STEEL
S13	#6 X 2" PFH SMS	ZINC PLATED STEEL

DOOR HARDWARE:

PART#	DESCRIPTION	MATERIAL
H11	MODEL 5000 BY VACHETTE	STEEL
H21	PIVOTA DX 300 3-D CP HINGES	BY BASYS

DOOR WEATHER STRIPPING:


PART#	DESCRIPTION	MATERIAL
W1	QEBD 650 KERF	BY SCHLEGEL
W3	QEZD 320 FLAT	BY SCHLEGEL



THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.

Pedro De Figueiredo
 10/19/2023

MODELS 1, 2, 3, 4, 5 AND 6 - FRAMING ANCHORAGE



ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
 9715 W. BROWARD BLVD.
 PLANTATION, FL 33324
 PPMF@AOL.COM
 ENGINEER SEAL
 PEDRO DE FIGUEIREDO
 PE 52609



Pedro De Figueiredo
 10/19/2023


THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.

PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
 LARGE & SMALL MISSILE
 IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
 222 NE 27TH STREET
 MIAMI- FLORIDA- 33137
 TEL: (561) 939-3368
 FAX: (877) 839-2220

SCALE:
 NA
 DATE:
 10/19/2023
 DRAWING #
 23-202
 SHEET
 14 OF 16


FRAMING ANCHORAGE DETAILS




OPTION 1
 FRAME MOUNTED DIRECTLY INTO SUBSTRATE WITH MAXIMUM 1/4" SHIM AND 1/4" ULTRACONS BY ELCO WITH 1 3/4" MIN. EMBEDMENT INTO GROUT FILLED MASONRY (JAMBS) OR INTO 3000 PSI CONCRETE
 (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT)




OPTION 2
 FRAME MOUNTED WITH MAXIMUM 1/4" SHIM AND MAXIMUM 1X PT CONTINUOUS WOOD SPACER SECURED BY 1/4" ULTRACONS BY ELCO WITH 1 3/4" MIN. EMBEDMENT INTO GROUT FILLED MASONRY (JAMBS) OR INTO 3000 PSI CONCRETE. FOR INSTALLATION INTO METAL STRUCTURES USE 1/4-20 HWH GRADE 5 SDS
 (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT)
 1X BUCK TO BE PROPERLY DESIGNED BY OTHERS.




OPTION 3
 FRAME MOUNTED DIRECTLY INTO 2X PT WOOD BUCK (SG >= 0.55) W/ MAX. 1/4" SHIM AND SECURED BY #14 SS WOOD SCREWS OR 1/4" ULTRACONS WITH 1 3/8" MIN. EMBEDMENT.
 (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT)
 2X BUCK TO BE PROPERLY DESIGNED BY OTHERS.




OPTION 4
 FRAME MOUNTED DIRECTLY INTO METAL STRUCTURES W/ MAX. 1/4" SHIM. 1/4"-20 PFH SDS GR 5 INTO MIN. 1/8" A36 STEEL OR 6063-T6 ALUMINUM.
 (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT)




QUALIFIED FRAME AND PANELS CONFIGURATIONS



RECTANGULAR XX
74X122




ARCHED XX
74X122




ELLIPTICAL XX
74X122




RECTANGULAR X
38X122




1/2 ARCHED X
38X122




1/2 ELLIPTICAL X
38X122




ELLIPTICAL X
38X122




ARCHED X
38X122





RECTANGULAR
PAIR O-XX-O -154X122
SINGLE O-X-O -118X122



ARCHED OR ELLIPTICAL O-XX-O
PAIR O-XX-O -154X122
SINGLE O-X-O -118X122




RECTANGULAR W/ TRANSOM
PAIR XX-O -74 1/2 X160 3/8
SINGLE X-O -38 3/8X160 3/8



Pedro De Figueiredo
10/19/2023



THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



ENGINEER/ARCHITECTS - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED




ALTERNATE DOOR PANELS
NOTES:
1- THESE ARE JUST FOR A FEW VARIATIONS OF MANY POSSIBLE COMBINATIONS.
2- COMBINATIONS OF ALTERNATE DOOR PANELS ARE ACCEPTABLE IF GLASS DLO AREA AND DLO WOOD PANEL AREA NOT TO EXCEED THE SIZES LISTED ABOVE:

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
15 OF 16

DOOR SASH AND FRAME ASSEMBLY



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.




PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI - FLORIDA - 33137
TEL: (561) 939-3368
FAX: (877) 839-2220


SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
16 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609



SASH CONSTRUCTION:

THE TOP, BOTTOM AND INTERIOR RAILS WERE RABBET AND BUTT JOINED WITH A 5 X 0.70X2" LONG MORTISE AND (5" - 8 1/2") X 3/4 X (2"-2 7/8") LONG TENON TO THE HINGE AND LOCK STILES USING GLUE. THE ASTRAGAL FOR INACTIVE LEAF WAS FIRST NAILED USING 18GA X1 BRAD NAILS AND GLUE FURTHER SECURED TO THE LOCK STILE USING (9) #6X1 1/2 PFH SMS AT 13 1/2"OC IN THE FIELD. THE ASTRAGAL FOR ACTIVE LEAF WAS FIRST NAILED USING 18GA X1 BRAD NAILS AND GLUE FURTHER SECURED TO THE LOCK STILE USING (10) #8X2" PFH SMS AT 12"OC IN THE FIELD. A DECORATIVE MOLDING WAS ATTACHED AROUND THE INTERIOR GLAZING AREAS USING 18GA X1 BRAD NAILS. THE RECESSES WERE MADE TO ACCEPT WEATHER STRIP AS DESCRIBED LATER IN THE REPORT.



FRAME CONSTRUCTION:

THE JAMBS WERE RABBET AND BUTT JOINED WITH SILL AND HEADER USING (3) #10X3" PFH SMS IN EACH CORNER AND SEALED USING SILICONE. THE JAMBS, HEADER AND SILL HAD A NOTCH CUT-OUT TO ALLOW THE PLACEMENT OF THE WEATHERSTRIPPING. AN ALUMINUM BAR WAS ATTACHED TO THE SILL TOWARD THE EXTERIOR EDGE AS WEAR STRIP AND ATTACHED BY USING #6X1 1/4" S5 PFH SMS AT 6 1/4" OC

SEALANT:
EXTERIOR PERIMETER WAS CAULKED WITH SIKAFLEX-1A SILICONE SEALANT. THE CUSTOM GLUE PART #M3 WAS USED TO GLUE THE MORTISE AND TENON JOINT, ASTRAGAL AND OTHER JOINTS AS WELL AS BUTCHER BLOCK CONSTRUCTION